

# McAllen Fire Prevention

## Food Trailer/ Truck Requirements

### NEW & EXISTING SUPPRESSION SYSTEMS FEE

- New and Existing suppression systems **will require** an ANNUAL inspection ONLY.  
Fee: **\$50.00**
- This is a Pass / Fail inspection.
- Re-inspection fee: \$50.00
- Trip test will NOT be witnessed.

### REQUIREMENTS Apply to NEW and EXISTING systems

- A Certificate of Installation is **REQUIRED**
- The VIN is **REQUIRED** on the Certificate of Installation.
- Inspection Tag **REQUIRED**
- Installation Label **REQUIRED**
- **REQUIRED** documentation "*by an approved inspection agency or a company that is registered with the US Dept. of Transportation ensuring that LP Gas system components are free from damage, suitable for the intended service and not subject to leaking.*" - IFC 2018 319.10.3. (A company letterhead will suffice).

-The above must be in place at time of inspection.

### ADDITIONAL REQUIREMENTS

- Placards advising no smoking, flammable gas, propane, etc., shall be installed
- Proper fire extinguisher coverage. (*Dry Chemical and Class K*).
- All cooking appliances, grease filters, extractors, and applicable hood components must be listed equipment. Acceptable listed equipment can be one of the following: UL-Underwriters Laboratories, Intertek(ETL), or with the Canadian standards association with the U.S. mark.
- LP Gas container construction shall be manufactured in compliance with the requirements of NFPA 58. Propane cylinders must be secured with a solid bracket. NO STRAPS.
- Propane Cylinder(s) shall be 200 lbs. aggregate or less IFC 319.8.1

Click to apply for permit and/or Inspection here