

# Sprinkler System Fee Schedule

Maintenance / Repair Fee: \$0.00		
No Fee	NO Plan Review	AHJ
No Fee	NO Permit	IFC- 105.1.5
No Fee	NO Inspection	AHJ
	Service Tag <b>REQUIRED</b>	TAC 34.719

Modification / Upgrade Fee: \$150.00 <i>21+ sprinkler heads</i>		
\$50.00	Plan Review with RME signature <b>REQUIRED</b>	IFC- 901.2
\$50.00	Permit <b>REQUIRED***</b>	IFC- 105.1.1; 105.7; 105.7.1 ; 105.7.8
\$50.00	Inspection <b>REQUIRED**</b> <i>- this is a pass or fail inspection</i>	IFC- 107.2; NFPA 13 - 25.2
	Updated Installation Tag <b>REQUIRED</b>	TAC 34.718

Modification / Upgrade Fee: \$150.00 <i>0-20 sprinkler heads</i>		
\$50.00	Plan Review with RME Signature <b>REQUIRED</b>	IFC 901.2
\$50.00	Permit <b>REQUIRED***</b>	IFC- 105.1.1; 105.7; 105.7.1; 105.7.8
\$50.00	Inspection <b>REQUIRED**</b> <i>- this is a pass or fail inspection</i>	IFC- 107.2      NFPA 13 - 25.2
	Updated Installation Tag <b>REQUIRED</b>	TAC 34.718; IFC 901.6.3

NEW Installations: \$400.00		
\$50.00	Hydrant Flow Test <b>REQUIRED</b>	NFPA 13 -23.2; 23.2.1
\$100.00	Plan Review with RME signature <b>REQUIRED*</b>	IFC- 901.2
\$50.00	Permit <b>REQUIRED***</b>	IFC- 105.1.1; 105.7 ; 105.7.1; 105.7.8
\$50.00	Spigot Inspection <b>REQUIRED**</b> <i>-this is a pass or fail inspection</i>	IFC- 107.2
\$50.00	Underground Hydro Inspection <b>REQUIRED**</b> Material & Test Certificate <b>REQUIRED</b>	IFC- 107.2 NFPA 13- 10.10.1; & Fig. 10.10.1
\$50.00	Flush <b>REQUIRED**</b> - <i>this is a pass or fail inspection</i>	IFC- 107.2      NFPA 13- 10.10.2.1
\$50.00	Aboveground Acceptance Test <b>REQUIRED**</b> Material & Test Certificate <b>REQUIRED</b> <i>- this is a pass or fail inspection</i>	IFC- 107.2 NFPA 13- 25.1; Fig. 25.1 25.2
	Installation tags <b>REQUIRED</b>	IFC- 901.6.3

\* Re-inspection plan review- \$100.00

\*\*Re-inspection fee - \$50.00

\*\*\*Working without permit- 1.5X permit fee and a citation **WILL** be issued.